

BOARDWALK HALL
LOADING DOCK MODIFICATIONS
ADDENDUM #3
FEBRUARY 28, 2020

BID CYCLE DATES:

- All Dates Remain Unchanged
- RFI period is closed

TECHNICAL SPECIFICATIONS:

- No modifications

DRAWINGS:

- No revisions

RFI RESPONSES (FINAL):

1. Clarify Bid Proposal Form as to Alternates and separate envelope for bond only
 - **See Addendum #2**
 - **Bond shall be submitted in separate envelope clearly marked “BOND” with project name and bidder’s name on envelope.**
2. Can local steel fabricators quote on alternate aluminum material?
 - **Yes, will require substitution request post award for approval.**
3. Can steel shop drawings calculations by professional engineer be waived, section 05120 1.3?
 - **No**
4. Verify thickness of existing concrete to be replaced
 - **Assume 8” to 12” thick**
 - **Reinforced**
5. Are Expansion or control joints required?
 - **No**
6. Specify joint sealant material and if pre-molded expansion joint material is required at perimeter and elsewhere
 - **Pre molded asphaltic expansion joint is required at cold joints**
 - **Seal with high quality butyl sealant**

All information contained within Addendum #1, #2 and Addendum #3 shall be incorporated within the contractor’s bid

END OF ADDENDUM #3