

TO: Bid Responders

FROM: Clark Hughes

DATE: February 16, 2017

SUBJECT: BOARDWALK HALL – WEST HALL DOOR REPLACEMENT – ADDENUM 1

A. SPECIFICATIONS

1. EXTERIOR DOORS:

- a. New FD55 HW FRP Fiberglass Faced Doors with 5 x20 LITE KITS 1” INSULATED TEMPERED CLEAR GLASS.
- b. DOOR HUNG ON FULL MORTSE CONTINOUS GEARED HINGES HEAVY DUTY SL24BRHD
- c. EXTERIOR DOORS WITH YALE 6100 SERIES GRADE 1 PANICS US 32D
- d. 2 ACTIVE TRIMS PULL HANDLE WITH CYLINDERS TO EXCEPT BEST I/C CORES
- e. REMOVABLE MULLIONS M200 SERIES WITH SEALS ON MULLIONS
- f. NORTON 7500 STOP ARM GRADE 1 DOOR CLOSERS DB
- g. FULL CAPING AND COVER OLD FINISHES ON EXISTING FRAME WORK
- h. 7” FULL THRESHOLDS RAPPIN FRAMES

2. INTERIOR DOORS:

- a. *New FD55 HW FRP Fiberglass Faced Doors with 5 x20 LITE KITS CLEAR TEMPERED GLASS.*
- b. *PUSH/PULL SETS ROCKWOOD BF15747. 10” CENTER TO CENTER OFFSET PULL WITH PUSH BAR CENTER TO CENTER 33”. FINISH US 32D.*
- c. FD55 HW FRP FIBERGLASS FACED DOORS

- d. BRONZE COLOR DOORS AND FRAMES FS2AB
- e. DOORS HUNG ON FULL MORTIS CONTINOUS HEAVY DUTY
- f. BRONZE ANODIZED SL24BRHD
- g. NORTON 7500 SERIES STOP ARM GRADE DOOR CLOSER DB
- h. 7" FULL THRESHOLD RAPPIN FRAMES AND DOOR SWEEPS
- i. FRP PANELS SAME COLOR AS DOORS CAPPING TRANSOMS
- j. LIGHTS OVER FRAME TO CEILING WITH BRONZE CAPPING BOTH SIDES OF TRANSOMES

B. QUESTIONS

1. Is painting of the interior vestibule space included in the bid?

Answer

No, unless there are damages as a result of this scope of work.

Atth: Attendance Sheet

Cc: Jim McDonald

Marie Remer

Spectra Venue Management Website | SpectraExperiences.com