



CLARK HUGHES

TO: Bid Responders

FROM: Clark Hughes

DATE: August 30, 2016

SUBJECT: BOARDWALK HALL - EXTERIOR DOORS - ADDENDUM #1

- 1) All interior wood material is to remain. Any wood material disturbed is to be patched, primed, caulked and painted.
- 2) Replacement doors shall be sized to completely fill all openings.
- 3) Install rain drip sweeps on all doors.
- **4)** Doors 19, 20, 21, 22, 23, 24 are removed from the bid. The base bid will be for (50) fifty doors.
- **5)** FRP doors are to be FD55 heavy duty rated.
- 6) For door # 34, install flush plate with door pull and cylinder. US 32 D finish.
- 7) Provide base bids for (50) fifty non-fire rated doors and (50) fire rated doors. Provide alternates for (28) twenty eight non-fire rated doors and (28) fire rated doors. Refer to attached revised Bid Form H.

Attached: Revised Bid Form H

Cc: Jim McDonald