



SPECTRA
BY COMCAST SPECTACOR

CLARK HUGHES

Capital Project Procurement Manager
Atlantic City Convention Center
Jim Whelan Boardwalk Hall
2301 Boardwalk, Atlantic City, NJ 08401
O: 609.348 - 7026 c: 609 226 - 3069
Clark.hughes@spectrap.com

TO: Bid Responders

FROM: Clark Hughes

DATE: January 30, 2020

SUBJECT: EXTERIOR LED BOARD REPLACEMENT; 2nd BID - ADDENDUM #1

1. What fiber optic cable now exists to the sign and from what location in the building does it terminate at?
 - a. The existing fiber cable is an armored 62.5/125 6-strand OM1 cable that terminates in the IDF 181 closet located between the arena and the West Hall.
2. What fiber micron, number of strands, multi or single mode?
 - a. The new cable should be at least a 50 micron, 6-strand, multi-mode armored Fiber cable.
3. What is the distance of the fiber run?
 - a. Approximately 700'
4. What was the closing date for questions?
 - a. Friday, January 24, 2020
5. Are substitutions considered?
 - a. Refer to Chapter 01451.12 Quality Requirements; section 01451.12 Substitution or Equal Items. In addition, provide manufacturer, make and model for all requests.
6. Please clarify what form needs to be in a separate, sealed envelope?
 - a. Refer to sections 1.15, 1.16 and 1.17.

ATTN: Guidelines
Sign-in Sheet

Cc: Jim McDonald
Chris Hartnett
Austin Gerber
Marie Remer