

TO: Bid Responders

FROM: Clark Hughes

DATE: April 8, 2026

SUBJECT: JWBWH LOBBY AUDIO VIDEO MODIFICATION – ADDENDUM #6

COMMENTS

1. Approved Equal

Please be advised that the ElationLogic ELD15 COB 1500NITS LED panel has been evaluated and confirmed to be an approved equal to the specified Neoti UHD-2 panel.

2. Scope of Work Modification

All new electric circuits and data as indicated on Sheet E-501 of the contract documents shall be installed using flexible armor cable above the plenum space above the lobby elevation level. All de-energized cables resulting from this new installation project shall be removed from the plenum space and disposed of as part of this project.

3. This Addendum #6 makes no changes to the bid due date of Monday, April 20, 2026, at 11:00 am, as set forth in Addendum #5

END OF QUESTIONS AND ANSWERS

Cc: Jim McDonald
Nicole Hagaman