ATLANTIC CITY CONVENTION CENTER

JIM WHELAN BOARDWALK HALL

OVG OAK VIEW GROUP

TO: Bid Responders

FROM: Clark Hughes (OVG), Dan Iversen (WATG)

DATE: November 6, 2026

SUBJECT: ACCC STAIRWELL EGRESS CONTROL PLAN – GENERAL CONTRACTORS AS NEEDED ADDENDUM #5

RFI Responses

1. *Do the garage cameras being replaced require new cabling and conduits run to the nearest IDF rack? If so, CAT6 cable and GameChanger cable won't carry the required voltage due to the lengths of these runs. Is 6-strand single-mode fiber optic cable acceptable for these cameras with runs that are 500LF+? For all cameras with runs longer than 300LF but less than 500LF, is GameChanger cable acceptable?*
   Yes, new cable is required.
   Gamechanger acceptable.
   If fiber is required, that is acceptable as well for over 500ft, please include any required equipment.

2. *Are the two pairs of doors from the garage to the end of the egress tunnel included with this project?*
   Yes, see attached location plan and photo with notes.

Comments

1. **Unit Prices for Cameras**
   Base bid: Fisheye Lens
   Provide Unit Pricing to upgrade Fisheye Lens to Quad Lens Camera
   Refer to revised bid form

2. Critical Date Change
   Refer to the attached

END OF ADDENDUM #5

ATTH: Revised Door Plan
Revised Critical Dates
Revised Bid Form

Cc: Jim McDonald
Jason Resetar
Nicole Hagaman
Dan Iversen

"EXHIBIT G"
ACCC STAIRWELL CONTROL PLAN
ADDENDUM #5

Schedule of Estimated Quantities, Unit Prices, and Lump Sum Items

Item	Description	Unit	Amount
1	Permits	L.S.	
2	Cost of Paint Materials and Labor	L.S.	
3	Cost of Cameras Material and Labor	L.S.	
4	Cost of Doors, Door Hardware Materials and Labor	L.S.	
5	Cost of Electric Materials and Labor	L.S	
6	Fire Alarm System Material and Labor	L.S.	
7	General Conditions	L.S.	
	TOTAL LUMP SUM	L.S.	

TOTAL LUMP SUM CONTRACT PRICE (Numerically) Line Item 1 through 7

_____

TOTAL LUMP SUM CONTRACT (In words) Line Items 1 through 7: _____

_____

_____

_____

_____**Dollars**

UNIT PRICE #1: The Bidder agrees to unit pricing for installation of one handle assembly on additional existing doors with panics on one side and nonfunctional trim opposite panic (show amount in both words and figures):

ADD **Per Door.**

$_____

UNIT PRICE #2: The Bidder agrees to unit pricing for door preparation for existing door with panic push side and no opposite side trim per door and new lever trim on opposite side of panic(show amount in both words and figures):

ADD **Per Door.**

$_____

UNIT PRICE #3: The Bidder agrees to unit pricing for installation of magnetic door closer, sensor, power supply and press to exit hardware on additional doors. Furnish and install 250′ cat 6 plenum rated cable with testing and terminations by contractor. Furnish and install a 20-amp, 120-volt feeder to include 150′ of #12 wire and 1 single pole breaker (show amount in both words and figures):

ADD **Per Door.**

$_____

UNIT PRICE #4: The Bidder agrees to provide unit pricing for camera and installation. Furnish and install 1 250′ cat 6 plenum rated cable with testing and terminations by contractor. (show amount in both words and figures):

ADD **Per Door.**

$_____

UNIT PRICE #5: Provide alternate price to furnish and install a 90-minute replacement door to match existing, utilizing existing hardware. Paint to match. Identify the quantity of doors with existing trim to be replaced where the specified replacement won't cover the previous hole.

ADD Per Door.

$_____

UNIT PRICE #6: Cameras – Base bid shall be based on Fisheye Lens. Provide unit pricing to upgrade Fisheye Lens to Quad Lens Camera

ADD **Per Camera**

$_____

ADDENDA: The Bidder acknowledges receipt of the following Addenda:

_____ Dated _____

_____ Dated _____

_____ Dated _____

_____Dated_____

_____Dated_____

_____Dated_____

Bidder Name: _____ Date: _____

By (print): _____

Signature: _____

Title: _____

ATLANTIC CITY CONVENTION CENTER

JIM WHELAN BOARDWALK HALL

OVG OAK VIEW GROUP

TO: Proposal Responders

FROM: Clark Hughes

DATE: November 6, 2026

SUBJECT: **ACCC STAIRWELL EGRESS CONTROL PLAN – GENERAL CONTRACTORS AS NEEDED CRITICAL DATE/TIME CHANGE - ADDENDUM #5**

RFI Responses

For:	**ATLANTIC CITY CONVENTION CENTER**
	STAIRWELL CONTROL PLAN **GENERAL CONTRACTORS** **ADDENDUM #5**

Bid Submission Due Date (Refer to BID Section 1.3 for more information.) **2301 Boardwalk, Atlantic City, NJ, 08401. Admin Office - Conference Room 160N**	TUESDAY NOVEMBER 17, 2026	11:00 AM 1100 HOURS